AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 30-04-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	23-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	30-04-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	456	15.2	15.44
2	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	466	15.4	
3	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	463	15.7	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 30-04-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	23-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	30-04-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	463	14.12	14.84
2	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	473	15.52	
3	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	470	14.89	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 30-04-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	23-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	30-04-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	470	15.15	15.31
2	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	480	15.13	
3	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	473	15.64	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 30-04-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	23-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	30-04-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	460	15.12	15.20
2	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	471	15.24	
3	Drain Raft	M20	23-04-2021	30-04-2021	150x150x150	22500	457	15.24	

Remarks :

Assistant Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 03-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	26-04-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	03-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in K.N	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	467	15.28	15.38
2	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	477	15.64	
3	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	464	15.21	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES
DATE
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 03-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	26-04-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	03-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	466	14.28	14.51
2	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	476	14.69	
3	Wall Concrete	M20	26-04-2021	03-05-2021	150x150x150	22500	463	14.57	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka
BBMP, Bangalore

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 06-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	29-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	06-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	473	15.24	11.59
2	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	483	14.87	
3	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	476	4.65	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 06-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	29-04-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	06-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	488	14.28	14.42
2	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	498	14.65	
3	Drain Raft	M20	29-04-2021	06-05-2021	150x150x150	22500	485	14.32	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 07-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	30-04-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	07-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	466	14.23	15.05
2	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	476	15.67	
3	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	469	15.24	

Remarks :

AE

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 07-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	30-04-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	07-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	456	14.23	14.58
2	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	466	14.65	
3	Wall Concrete	M20	30-04-2021	07-05-2021	150x150x150	22500	452	14.87	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 10-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-05-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	455	15.43	15.43
2	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	462	15.23	
3	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	452	15.64	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES
BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 10-05-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	03-05-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	10-05-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	453	14.58	15.16
2	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	472	15.67	
3	Drain Raft	M20	03-05-2021	10-05-2021	150x150x150	22500	460	15.24	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 06-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	29-06-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	06-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	463	14.25	14.43
2	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	481	14.35	
3	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	469	14.68	

Remarks :

Asst. Exective Engineer
Project Division
Yelahanka
BBMP, Bangalore - 92

AARTN ASSOCIAT
DATE
BANG

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 06-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	29-06-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	06-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	468	14.25	14.97
2	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	466	15.28	
3	Wall Concrete	M20	29-06-2021	06-07-2021	150x150x150	22500	471	15.38	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 08-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	01-07-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	08-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	471	14.21	14.40
2	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	469	14.35	
3	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	474	14.65	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGA

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 08-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	01-07-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	08-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	463	14.23	14.62
2	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	461	14.65	
3	Drain Raft	M20	01-07-2021	08-07-2021	150x150x150	22500	466	14.98	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 12-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	05-07-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	12-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	460	15.23	15.21
2	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	458	15.42	
3	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	463	14.98	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 12-07-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	05-07-2021
Sample Type	Wall Concrete
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	12-07-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	458	15.23	15.58
2	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	456	15.64	
3	Wall Concrete	M20	05-07-2021	12-07-2021	150x150x150	22500	461	15.87	

Remarks :

Asst Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 17-08-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	10-08-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	17-08-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	450	14.21	14.41
2	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	448	14.67	
3	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	453	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 17-08-2021

Name of Work : Improvements to roads and drian at western side of hegdenagara 2nd main road from 1st cross to 7th cross and surrounding Areas in ward No.06

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. K S Chowdareddy
Customer Reference	EE(Project)YNK Zone/WO/191/2020-21
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	10-08-2021
Sample Type	Drain Raft
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M20/ 7 Days Compressive Strength
Date of Test	17-08-2021
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm^2	N/mm^2
1	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	458	14.25	14.47
2	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	456	14.80	
3	Drain Raft	M20	10-08-2021	17-08-2021	150x150x150	22500	461	14.35	

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES BANGALORE